RE-USE OF TREATED SEWAGE USING BIOFILTER TECHNOLOGY

E. Craig Jowett, Ph.D., P.Eng.
Waterloo Biofilter Systems Inc.
143 Dennis Street, Rockwood, ON N0B 2K0
www.waterloo-biofilter.com

INTRODUCTION

Re-use of highly treated sewage is a positive step in managing water supplies, and can be defined as "indirect" (i.e., after passage through the groundwater table or through a treatment plant), or "immediate" (i.e., used right away in the house for toilets, laundry, irrigation, etc.). Immediate re-use is usually met with reluctance, even though people may acknowledge that their potable water was once sewage wastewater some time in the past. People may also swim in river water much dirtier than highly treated sewage without problem: the sense of immediacy is not there. However, once the treatment system is seen to be robust, and the water quality consistent, our experience is that this initial reluctance is overcome, and immediate re-use is accepted by golf course staff and homeowner alike.

This paper describes several sites in Canada and Korea where sewage is treated by the WATERLOO BIOFILTER absorbent trickle filter technology (Jowett et al., 2000). The WATERLOO BIOFILTER foam medium forms an interconnecting, three-dimensional reticulate solid framework with high surface area, high porosity, high absorption, and dual pathways for air and wastewater (Jowett, 1997b; Jowett, 1999) and is detailed in Jowett and McMaster, 1995 and Crites and Tchobanoglous, 1998.

WATER RE-USE PARAMETERS

The following criteria and guidelines for water re-use are taken from Jowett, 1997a. For swimming and bathing, the water should be aesthetically pleasing, and without objectional colour, odour, taste, or turbidity. Because of eye irritation, the pH should be within the range of 6.5 to 8.5. The use of the water should also not

NORTH BAY RESIDENCE: SWIMMING WATER QUALITY WITH NO ACTIVE DISINFECTION

A demonstration site installed by the City of North Bay uses a WATERLOO BIOFILTER to treat septic tank effluent followed by a small up-flow filter to remove phosphorus (Hutchinson and Jowett, 1997) (Fig. 1). This site is not designed for re-use, but the effluent is consistently clean enough to be meet all EPA criteria, without further disinfection, for swimming or toilet flushing. Table 1 shows the system performance with an initial 6 months using red sandy soil in the up-flow filter, and the last 12 months using expanded clay aggregate.

Table 1. North Bay domestic sewage analyses after Waterloo Biofilter and up-flow filter treatment 1998-1999; n = number of samples; OUT = arithmetic mean

Parameter	Jan 98 to Jun 98 soil up-flow			Jul 98 to Aug 99 expanded clay up-flow		
	n	OUT mg/L	% removal	n	OUT mg/L	% removal
BOD_5	6	<5	~95	7	~5	~95
TSS	6	<2	>94	7	<5	>94
TN	6	19	~50	7	20	~50
E.coli CFU/100mL	4	660	>99	18	<29	99.98

An astonishing aspect of this trial, and one important to wastewater re-use, is the excellent removal of coliforms in the up-flow filter. After 6 months, the effluent had <75 CFU/100mL and dropped to <16 in the last six months (Fig. 2), approaching what UV disinfection can achieve. These and other results increase confidence for lower level re-uses such as toilet flushing or garden use, without the need for high-maintenance disinfection.

CLUBLINK GOLF COURSES: IRRIGATION RE-USE OR SURFACE DISCHARGE

The sewage treatment system at CLUB INK S designed to handle the large fluctuations in flow rates typical of a major golf course hosting social functions and tournaments. CLUBLINK'S criteria were to treat the effluent to a very high degree so that their wastewater would become a useful resource for golf course irrigation. Average flows of 60 m^3/d with 5-day peaks of 120 m^3/d at 250 mg/L cBOD were the design loadings. Due to commercial success of the golf course and water conservation measures, higher organic loadings of 400-1200 mg/L cBOD and 200-500 mg/L TSS are typical, but the treatment system is handling the high organic and nitrogen loading.

The treatment system (Fig. 3) includes: (1) a raw sewage pumping station, (2) 3-day capacity septic tanks with fine-screen effluent filters, (3) 1-day capacity recirculation and pump tank to dose the BIOFILTER, (4) WATERLOO BIOFILTERS in 6 poured-in-place concrete tanks, (5) 120 m^3/d recirculation design for BOD and ammonium removal and for mitigation of hydraulic surges, (6) alum addition to the septic tanks for phosphorus and solids removal, and (7) ultraviolet disinfection for the final BIOFILTER effluent. Other important aspects of the design are (8) a custom electronic remote monitoring system, and (9) professional operations management secured by CLUBLINK. The system started up in mid-May 1999, and within one month, was within compliance (Table 3). The water is diverted to irrigation ponds, now a useful resource. Staff members nervous about re-using wastewater in their irrigation lines were shown the facility, and after seeing the clarity of the effluent, they were comfortable with using it.

Blue Springs golf club has a similar process design with flow rates of 30 m

Table 3. Waterloo Biofilter effluent at two ClubLink golf courses, August 1999 to January 2001, n = number of samples; OUT = median 50 perc08.er effluent at

“HEALTHY HOUSE” SYSTEM: IMMEDIATE HIGH-LEVEL RE-USE

Even more confidence is required by the regulator to allow for immediate re-use of treated wastewater in a house, for low-level uses such as toilets, but especially for high-level uses such as laundry, baths and showers. Other papers on the CMHC’s Toronto “Healthy Houses” have been written (Townshend et al., 1997), and this design is now well known because the treated wastewater has been re-used immediately in the houses for toilets, laundry, and baths and showers since 1996. The technology has been transferred to the Canadian Arctic where water supply is difficult and expensive. The septic tank is a flexible bladder tank and the B

Crites, R., and G. Tchobanoglous, 1998. Small and decentralized wastewater management systems. McGraw-Hill, 1084 pp.

Hutchinson, N. J., and E. C. Jowett, 1997. Nutrient abatement in domestic septic systems: research initiatives of the Ontario Ministry of Environment, In: Septic Odour, Commercial Wastewater and Phosphorus Removal, WCGR, May 5, University of Waterloo, E. C. Jowett, (Ed.), pp. 81-102.

Jowett, E. C., 1997a. Sewage and leachate wastewater treatment using the absorbent Waterloo Biofilter, In: ASTM STP 1324, Site Characterization and Design of On-Site Septic Systems, American Society for Testing and Materials, West Conshohoken PA, M. S. Bedinger, A. I. Johnson, and J. S. Fleming (Eds.), pp. 261-282.

Jowett, E. C., 1997b. Design and start-up of domestic wastewater re-use system in the CMHC Toronto "Healthy House", National Onsite Wastewater Recycling Association 6th Annual Conference, October 24, 1997, College Station, Texas.

Jowett, E. C., 1999. Immediate re-use of treated wastewater for household and irrigation purposes, In: Proceedings, 10th Northwest On-Site Wastewater Treatment Short Course and Equipment Exhibition, September 20-21, 1999, University of Washington, Seattle, R.W. Seabloom, (Ed.), pp. 115-126.

Jowett, E. C., and M. L. McMaster, 1995. On-site wastewater treatment using unsaturated absorbent biofilters, Journal of Environmental Quality. vol. 24, pp. 86--95.

Jowett, E. C., Danilovic, I., Kimn, B., Kim, S., and Keightley, P., 2000. Consistency of treated wastewater needed for household, irrigation, and near-potable re-use, National Onsite Wastewater Recycling Association 9th Annual Conference Proceedings, pp. 205-215

Millham, N. P., Heufelder, G., Howes, B., and Costa, J., 2000. Performance of three alternative system technologies and a conventional septic system, Environment Cape Cod,. vol. 3, pp. 49-58.

Townshend, A. R., E. C. Jowett, R. A. LeCraw, D. H. Waller, R. Paloheimo, C. Ives, nc e3, pp. 49-tTd[4, pp